




You'll be over the moon!



SUMMARY

FULL	33
VISUAL	24
EMISSIONS	1
FUSES CHANGED	1
PLUGS CHANGED	1
REPAIRS	1
FAILS	1
TOTAL NUMBER OF TESTS	58

NUMBER OF TESTS 12 MONTHS	26
NUMBER OF TESTS 24 MONTHS	32
NUMBER OF TESTS 36 MONTHS	0



ADDRESS	CLIENT	ENGINEERS	DATE TESTED	SITE CODE	APPLIANCE NUMBER	ITEM DESCRIPTION	FAILED ITEMS SUMMARY LOCATION	REASON FOR FAIL
8 ROWE ASH WAY LOCKS HEATH SOUTHAMPTON HANTS SO31 7EY	LUNA TESTING LTD	LYCAN THORPE JAY SPIERS SHAUN EATON	1ST JANUARY 2018	1	236436	PHONE CHARGER	MAIN OFFICE	DAMAGED EARTH PIN

Equip No	Description	Freq (months)	Location	Status	Test	Class	Engineer	Tester No	Polarity	Earth Continuity	Insulation Reading	Insulation Status	Leakage Status	Continuity Status	Change Plugs	Repairs	Change Fuses	FAILS
236428	PHONE CHARGER	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236429	PHONE CHARGER	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236430	P S U	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236431	CLASS II LEAD	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236432	P S U	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236433	CLASS II LEAD	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236434	P S U	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236435	CLASS II LEAD	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236436	PHONE CHARGER	12	MAIN OFFICE	FAIL	VISUAL	2	LT	238-0062	S	0	0	S	S	S				DAMAGED EARTH PIN
236437	P S U	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236438	CLASS II LEAD	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S			3 AMP	
236439	PHONE CHARGER	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236440	P S U	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236441	CLASS II LEAD	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236442	V D U	12	MAIN OFFICE	PASS	FULL	1	LT	238-0062	S	0.34	57	P	S	P				
236443	V D U	24	MAIN OFFICE	PASS	FULL	1	LT	238-0062	S	0.41	199.1	P	S	P				
236444	V D U	24	MAIN OFFICE	PASS	FULL	1	LT	238-0062	S	0.42	199.1	P	S	P				
236445	V D U	24	MAIN OFFICE	PASS	FULL	1	LT	238-0062	S	0.41	199.1	P	S	P				
236446	I E C LEAD	24	MAIN OFFICE	PASS	FULL	1	LT	238-0062	P	0.33	199.1	P	S	P	X			
236447	I E C LEAD	24	MAIN OFFICE	PASS	FULL	1	LT	238-0062	P	0.25	199.1	P	S	P				
236448	I E C LEAD	24	MAIN OFFICE	PASS	FULL	1	LT	238-0062	P	0.24	199.1	P	S	P				
236449	I E C LEAD	24	MAIN OFFICE	PASS	FULL	1	LT	238-0062	P	0.13	199.1	P	S	P				
236450	EXTENSION LEAD	24	MAIN OFFICE	PASS	FULL	1	LT	238-0062	P	0.17	199.1	P	S	P				
236451	EXTENSION LEAD	24	MAIN OFFICE	PASS	FULL	1	LT	238-0062	P	0.25	199.1	P	S	P				
236452	DESK SOCKET	24	MAIN OFFICE	PASS	FULL	1	LT	238-0062	P	0.24	199.1	P	S	P				
236453	DESK SOCKET	24	MAIN OFFICE	PASS	FULL	1	LT	238-0062	P	0.19	199.1	P	S	P				
236454	KETTLE	12	KITCHEN	PASS	FULL	1	LT	238-0062	S	0.17	199.1	S	S	S				
236455	KETTLE BASE	12	KITCHEN	PASS	FULL	1	LT	238-0062	S	0.19	199.1	S	S	S				
236456	MICROWAVE	12	KITCHEN	PASS	FULL	1	LT	238-0062	S	0.12	199.1	S	S	S				
236457	MICROWAVE	12	KITCHEN	PASS	EMISSION	1	LT	238-0062	S	0	0	S	S	S				
236458	WASHING MACHINE	12	KITCHEN	PASS	FULL	1	LT	238-0062	S	0.22	199.1	S	S	S				
236459	FRIDGE	12	KITCHEN	PASS	FULL	1	LT	238-0062	S	0.35	199.1	S	S	S				
236460	PHONE CHARGER	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				CUT BACK AND REPAIRED LEAD
236461	PHONE CHARGER	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236462	BATTERY CHARGER	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236463	BATTERY CHARGER	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236464	P S U	12	MAIN OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236465	PRINTER	24	MAIN OFFICE	PASS	FULL	1	LT	238-0062	S	0.2	199.1	P	S	P				
236466	I E C LEAD	24	MAIN OFFICE	PASS	FULL	1	LT	238-0062	P	0.2	199.1	P	S	P				

Equip No	Description	Freq (months)	Location	Status	Test	Class	Engineer	Tester No	Polarity	Earth Continuity	Insulation Reading	Insulation Status	Leakage Status	Continuity Status	Change Plugs	Repairs	Change Fuses	Fails
236467	V D U	24	SIDE OFFICE	PASS	FULL	1	LT	238-0062	S	0.41	199.1	P	S	P				
236468	I E C LEAD	24	SIDE OFFICE	PASS	FULL	1	LT	238-0062	P	0.21	199.1	P	S	P				
236469	P S U	24	SIDE OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236470	P S U	24	SIDE OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236471	CLASS II LEAD	24	SIDE OFFICE	PASS	VISUAL	1	LT	238-0062	S	0	0	S	S	S				
236472	CLASS II LEAD	24	SIDE OFFICE	PASS	VISUAL	2	LT	238-0062	S	0	0	S	S	S				
236473	EXTENSION LEAD	24	SIDE OFFICE	PASS	VISUAL	1	LT	238-0062	S	0	0	S	S	S				
236474	PROJECTOR	24	MEETING ROOM	PASS	FULL	1	LT	238-0062	S	0.25	199.1	P	S	P				
236475	I E C LEAD	24	MEETING ROOM	PASS	FULL	1	LT	238-0062	P	0.23	199.1	P	S	P				
236476	EXTENSION LEAD	24	MEETING ROOM	PASS	FULL	1	LT	238-0062	P	0.26	199.1	P	S	P				
236477	EXTENSION LEAD	24	MEETING ROOM	PASS	FULL	1	LT	238-0062	P	0.27	199.1	P	S	P				
236478	I E C LEAD	24	MEETING ROOM	PASS	FULL	1	LT	238-0062	P	0.19	199.1	P	S	P				
236479	CONFERENCING UNIT	24	MEETING ROOM	PASS	FULL	2	LT	238-0062	S	0	199.1	P	S	S				
236480	TELEVISION	24	MEETING ROOM	PASS	FULL	2	LT	238-0062	S	0	199.1	P	S	S				
236481	CLASS II LEAD	24	MEETING ROOM	PASS	FULL	2	LT	238-0062	S	0	199.1	P	S	S				
236482	C P U	24	MEETING ROOM	PASS	FULL	1	LT	238-0062	S	0.3	199.1	P	S	P				
236483	I E C LEAD	24	MEETING ROOM	PASS	FULL	1	LT	238-0062	P	0.17	199.1	P	S	P				
236484	EXTENSION LEAD	24	MEETING ROOM	PASS	FULL	1	LT	238-0062	P	0.2	199.1	P	S	P				
236485	EXTENSION LEAD	24	MEETING ROOM	PASS	FULL	1	LT	238-0062	P	0.16	199.1	P	S	P				